

ShortFall Request for Prasa Infocom & Power Solutions P Ltd

Issued on July 9, 2021

(To be submitted by July 15, 2021, 6:00 PM IST)

1. Noise level of the PAC: Is the 70 dBA noise level you have provided in the shortfall document for 1m or 2m distance. Note that the tender requires 70 dbA for 1m distance?
2. What is the difference of the above noise level from the 44 dBA sound pressure that is mentioned?
3. Indicate ducting to the outdoor unit in the diagram provided in your original tender in page 69.

Adequate justifications will have to be provided wherever deviations are made from the tender,