

ShortFall Request for TF Air Systems Pvt Ltd

Issued on July 9, 2021

(To be submitted by July 15, 2021, 6:00 PM IST)

1. Bidders eligibility criteria: Clause 2 related to record for the bidder to have maintained cooling solutions for a year in the specified period is still missing.
2. Noise level of the PAC is provided as 65 dBA at 2m distance. The tender asks for 70 dBA at 1m distance. Please confirm.
3. Electrical paneling information should be provided in a detailed manner.
4. Network cable tray: Is it ceiling or rack mounted?
5. Design layout diagram in page 100 of the shortfall document
 - a. Space for panels not provided at the north (top) side. Refer to our tender diagram.
 - b. Doors not provided at the west as required in the tender.
 - c. Ducting provided to the south, but should be to the west as per the tender.
 - d. The bidder should refer to the diagrams provided in the tender and conform to the design. Modified diagram should be given in this shortfall response.

Adequate justifications will have to be provided wherever deviations are made from the tender,